

QUESTIONS AND ANSWERS IV FOR:

RFP # 20-49, 10/21/2020 FOR

RFB for TWO (2) 20 MVA, 115 TO 13.2Y/7.62 kV POWER TRANSFORMER

WITH LOAD TAP CHANGER FOR SUGG PARKWAY & SPARE

Question:

1. Is a High-Voltage De-Energized No-Load Tap-Changer Switch required? We see that an LTC is required on the Low-Voltage.

Answer: A High-Voltage De-Energized No-Load Tap-Changer Switch is not required.