

Pre-Bid General Information

- Overhead Services are not to be trimmed.
- Door knockers must be used prior to trimming to notify customers.
- Poles must have 6 ft of clearance around them, guy pockets must be trimmed as well.

Pre-Bid Meeting Q&A

1. Q: Are we supposed to mow underbrush?
A: Yes, if trimming is required, the underbrush must be mowed as well.
2. Q: What is the minimum clearance for vegetation?
A: 10' foot minimum clearance for all vegetation (slow growers too)
3. Q: How much transmission right-of-way was hot-spotted between Walmart (Greenville Blvd) and Vernon-White Rd?
A: Approximately 2.37 miles
4. Q: Is there any back lot trimming required?
A: Yes, there are areas that will require back lot trimming. Example: Colonial Heights Subdivision and along Sylvan Dr.